

November 17, 2005

ANDRY RASMUSSEN & SONS, INC.
JEFF RASMUSSEN
PO BOX 66
CABLE WI 54821

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ANDRY RASMUSSEN & SONS, INC.
Product Name: NIBBLER
Model Number(s): 800
NIBBLER JR NJRG-002, OR NJRL-002
(58" LL, 13.5 GAL/IN., 36" MAX. DEPTH OF BURY, 375 G.P.D. FOR NIBBLER JR WHEN
USED TO TREAT RESIDENTIAL WASTEWATER BASED ON A 6 MONTH SERVICE
INTERVAL)
Product File No: 20050784

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- The products produced by this manufacturer are approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or manhole in lieu of observation/vent opening.
 - Bottom pipe opening for siphon, pump and holding tanks.
 - Optional discharge opening from riser.
 - This product is approved to use Polylok II "High Pressure Seal", Press Seal "Cast-A-Seal", 4" fernco #44U-405 gasket, 4" Multi-Tite, 4" Jone-Tite SV gasket mechanical adapters for all pipe connections.
 - This product is approved to use Lead and Oakum joints for all pipe connections.
 - Tank covers may be sealed by the use of mortar or rubber butyl sealant.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- The manhole cover installed above the Nibbler Jr. must be installed so that it terminates at or above grade.
- This tank must only be used in conjunction with the Nibbler Jr. sewage treatment apparatus and in accordance with the Nibbler Jr.'s product approval stipulations.
- This tank must be designed to withstand the pressures to which it will be subjected.

ANDRY RASMUSSEN & SONS, INC.

Page 2

November 17, 2005

Product File No: 20050784

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on March 19, 2001, under product file number 20002196.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002196.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mbeckwith@commerce.state.wi.us